



NOTES:

1. SAWED TRAVERSE CONTRACTION JOINTS SHALL BE SPACED:
20' IN PAVEMENT \geq 8" THICK;
15' IN PAVEMENT < 8" THICK.
2. REFER TO TYPICAL PAVEMENT SECTION FOR LONGITUDINAL JOINT SPACING.

SPACING DIAGRAM FOR TRANSVERSE JOINTS

N.T.S.

REINFORCED CONCRETE PAVEMENT
TRANSVERSE JOINT SPACING

North Central Texas Council of Governments



STANDARD SPECIFICATION REFERENCE

303.5.4.

DATE

OCT. '04

STANDARD DRAWING NO.

2060